



Tender No: 09/2025

Dated : 17.03.2025

**Corrigendum**

**Tender for Non-Comprehensive Annual Maintenance contract  
(AMC) for HT Panels, Transformers and Earthing  
pits at IIITD Campus Okhla Phase-III New Delhi110020**

S. No	Tender Specs/Clause	Reply
1	Ref Page no -4 - Scope of works VCB Panel 11 KV 800 AMP – 4 Nos (Including incomer and outgoing)	Ref Page no -4 - Scope of works VCB Panel 11 KV 800 AMP – <b>2 Nos incomer + 4 Nos outgoing including 1 no spare</b> (Including incomer and outgoing)

**PE & EO  
IIIT-Delhi**