



Tender for HVAC works for Tinkering Lab extension of R & D Block in Phase II construction of Campus of Indraprastha Institute of Information Technology (IIIT-Delhi) Campus, Okhla Phase-III, New Delhi.

AMENDMENT-1

Item S. No. as per BOQ	Item	Suggestions	Amended To
2	Chilled Water Hi-Wall Unit	None of the approved manufacturers i.e. M/s. Edgetech/Caryaire/Midea manufactures the 1.5 Ton Chilled Water Hi-Wall Unit with 3 rows cooling coil. M/s. Caryaire and Midea manufacture 1.5 Ton Chilled Water Hi-Wall Unit with 2 rows cooling coil. Please change numbers of rows from 3 to 2 of cooling coil.	Please consider 2 Row cooling coil.
4.2 and 4.2.1	Y-Strainer 50 MM	Please include “ Honeywell ” make in list of approved makes.	Acceptable, Honeywell is included as one of the approved makes.
4.3	PICB Valve	Please include “ Honeywell ” make in list of approved makes Is this item with thermostat or without thermostat?	Acceptable, Honeywell is included as one of the approved makes.. It is to be with thermostat.
4.4.3	Ball Valves 15 MM	Is this item with Strainer or without Strainer?	This item is with Strainer
4.5 and 4.5.1	2 Way ON/OFF Valve 25 MM	Kindly delete “Full stroke modulation” words from the description of this item as it is 2 way Valve of On /Off type. Is this item with thermostat or without thermostat?	This is 2 Way Type & same is to be provided with thermostat. ‘Full Stroke Modulation’ to be ignored.
7 to 7.3.1	Ducting	None of the approved manufacturers i.e. M/s. Ductofab/Zeco/Rollastar/ MK Ducting/IQRA manufactures ducting with powder coating. This item and it is not practically feasible to get the powder coating done of factory fabricated large pieces of duct. Also, the powder coating will peel-off during assembling and erection process. Please change the finishing from powder coating to spray paint.	Please quote for same ducting without any painting /spray painting/ powder coating.
10 to 10.2	Grilles / Diffuser	Please include the “Flowel” make in the list of approved makes.	Acceptable, Flowel is included as one of the approved makes
11 and 11.1	Fresh air Louvers	Please include the “Flowel” make in the list of approved makes.	Acceptable, Flowel is included as one of the approved makes
12	Volume Control Damper	Please include the “Flowel” make in the list of approved makes.	Acceptable, Flowel is included as one of the approved makes
17	Industrial type propeller fan	Please mention Air Volume Flow rate (CFM) and makes. –	Makes– Daspass/Caryaire/Khaitan. For CFM details Pl refer BOQ item. Minimum 10000 Cmh

LAST DATE OF SUBMISSION 1ST DEC 2020 BY 3:00 PM**OPENING OF BIDS****1ST DEC 2020 AT 3:30 PM**