



REPLIES TO QUERIES I		Ref: Tender No. 07/2021 and 5th Aug 2021	
Annual Running Operation and Maintenance Contract of 02X 65 KLD + 02 x 90 KLD STP plants at IIITD Camps			
S NO	QUERY DESCRIPTION	QUREY FROM VENDOR	REPLY
1	Rate Repair and maintain treated water tank and testing at inlet and outlet (for one month) - (Page.No- 34_tendernotice_Point_6)	It is not clear that Which Type of repair of treated water tank you want. Kindly clarify	For minor repairs and maintenance of treated water tank and only testing required for inlet and outlet water in the every month and also requires media to be change as per requirement of client
2	The Contractor will also provide a Tests Certificate every month of effluent water before and after treatment and certificate have to be Obtained from the Delhi Pollution Control Board, For B.O.D, C.O.D, PH, TSS, and O&G etc. as called for. (Page.No- 14_tendernotice_Point_ix)	1.Raw sewage sample need not to be tested as raw water parameter does not affect treatment procedure only treated water sample has to be tested. 2.As per NIT testing of treated water is from Delhi Pollution Control Board, but NABL lab sufficient for treated water parameter. So kindly allow to NABL lab.	Testing required for inlet and outlet water in the every month from NABL lab/DPCC as called for . The agency will obtain approval/permission/compliance report from DPCC/any other statutory body, as applicable and as required, for operation of sewage treatment plant etc in case same is called for.
3	On page 1 the price of tender document is mentioned Rs.2360/-, However it is available on your site and we have downloaded the same with the help of link provided by you => where ?	Do we have to pay the tender cost ? If yes how and where	Yes as per process indicated in tender.
4	On Page No. 34 Item No. 4 (Rate of Filtration and Treatment etc.)(For one Month)=>>>	what does this mean? Is it the cost of filter media in ACF and MGF ,which should be changed or anything else- Please clear.	Yes . it the cost of filter media in ACF and MGF ,which should be changed .